













CONNECTION EVALUATION

Keystone Unit: Compac
Manufacturer: Mirafi
Geogrid Type: 8XT
Laboratory: TRI Texas 5/2/2002


Peak Connection Equation Fit

	English	Metric
Intercept (plf)	1098	16.02
Slope1	35.5	35.5
Break - Normal	2161	31.54
Slope2	0.0	0.0
Maximum (plf)	2639	38.52

3/4" Serviceability Equation Fit

Intercept (plf)	742	10.83
Slope1	34.0	34.0
Break - Normal	2306	33.65
Slope2	6.2	6.2
Maximum (plf)	2414	35.22

Laboratory Test Data

[illegible]

CONNECTION EVALUATION

Keystone Unit:	Compac	
Manufacturer:	Mirafi	
Geogrid Type:	10XT	
Laboratory:	TRI Texas	5/13/2003

Peak Connection Equation Fit

	English	Metric
Intercept (plf)	1131	16.51
Slope1	38.1	38.1
Break - Normal	3003	43.83
Slope2	0.0	0.0
Maximum (plf)	3486	50.87

3/4" Serviceability Equation Fit

Intercept (plf)	1101	16.07
Slope1	25.7	25.7
Break - Normal	1613	23.54
Slope2	12.3	12.3
Maximum (plf)	2180	31.82

Laboratory Test Data

[illegible]